



EXISTING CROSSOVER TO BE REINSTATED WITH KERB & GUTTER AS PER COUNCIL SPECIFICATIONS.

STREET

600x600x600(D) SUMP WITH 'PRENCO' DRAIN WARDEN OR SIMILAR. (TYPICAL)

ENCASE PIPE WITH 100mm THK. CONC.

NEW CROSSOVER TO BE IN ACCORDANCE WITH COUNCIL REQUIREMENTS. (TYPICAL)

MANTHORPE

PROVIDE 10000L UNDERGROUND TANK WITH PUMP SET TO 11.1L/s.

CREATE RISING MAIN FROM THE PUMP AND CONNECTS TO BOUNDARY SUMP.

600x600x900(D) CONCRETE SUMP.

PROVIDE 225Ø REINFORCED CONCRETE PIPE & DISCHARGE TO COUNCILS UNDERGROUND STORMWATER DRAIN IN ACCORDANCE WITH COUNCIL STANDARD SK1019.

GUM

**PUMP NOTE:**  
 1. USE TWO PUMPS (11.1L/s EACH) TO BE CONFIGURED TO AUTOMATICALLY ALTERNATE AS THE DUTY PUMP & AUTOMATICALLY REVERT TO THE ALTERNATE PUMP SHOULD THE DUTY PUMP FAIL.  
 2. VISUAL & AUDIBLE ALARM TO BE INSTALLED FOR PUMP FAILURE. (FOR MORE INFORMATION REFER TO MANUFACTURER'S SPECIFICATIONS.)

**TYPICAL CONCRETE KERB**

PROVIDE SL62 FABRIC PLACED CENTRALLY

**TYPICAL CONCRETE KERB & GUTTER DETAIL**

PROVIDE SL62 FABRIC PLACED CENTRALLY

**SITE & DRAINAGE PLAN**  
 SCALE 1:200  
 AVENUE

**SITE LEVEL BY OTHERS**

NOTE: PUMP TO BE USE TO CLEAR SW IN U/G TANK AND BESIDES USE AS LANDSCAPE PURPOSE.

**SITE NOTES**

- S1. THIS IS AN ENGINEERING SURVEY PLAN AND SHOULD NOT BE TAKEN AS A CADASTRAL OR IDENTIFICATION SURVEY.
- S2. THE REDUCED LEVELS SHOWN ON THIS PLAN ARE TO BE REGARDED AS INDICATIVE ONLY. THEIR SUITABILITY SHOULD BE ASSESSED ON SITE BY THE BUILDER BUT SHOULD NOT BE LOWERED WITHOUT FIRST CHECKING I.P. LEVELS.
- S3. THE OWNER SHOULD BE AWARE THAT IT MAY BE MORE PRACTICAL TO CONSTRUCT THE RETAINING WALLS SHOWN ON THIS PLAN PRIOR TO THE COMMENCEMENT OF CONSTRUCTION OF THE BUILDING.
- S4. THE OWNER SHALL PROVIDE ADEQUATE PROPPING/BRACING ETC. TO ANY EXISTING BOUNDARY STRUCTURE OR WALL ON OR NEAR THE BOUNDARIES IMMEDIATELY AFTER SITE EXCAVATION.
- S5. PROVIDE ADEQUATE PROTECTION OR COVER TO STORM WATER PIPES I.E. 150mm AND WHERE PIPE IS TO BE SUBJECTED TO VEHICULAR LOADING 300mm MIN. COVER IS REQUIRED, OR ENCASE PIPE IN 100mm THICK CONCRETE. IT IS RECOMMENDED TO USE GALVANIZED BOX SECTION BETWEEN BOUNDARY AND STREET WATERTABLE.
- S6. MAXIMUM LEVEL OF PATH AT FLOOD GULLY TO BE 165mm BELOW FINISHED FLOOR LEVEL.
- S7. ALL STORMWATER WORKS AND RETAINING WALLS ARE TO BE CONSTRUCTED BY THE OWNER UNLESS STATED OTHERWISE IN THE BUILDERS CONTRACT.
- S8. ALL BUILDINGS, STRUCTURES AND TREES AFFECTING OR AFFECTED BY PROPOSED BUILDING WORKS HAVE BEEN SHOWN ON THIS PLAN.
- S9. REMOVAL OF ALL EXCESS SPOIL FROM SITE CUT & FOOTING EXCAVATION IS THE OWNERS RESPONSIBILITY UNLESS NOTED OTHERWISE BY THE BUILDER.
- S10. THE DRAINAGE LAYOUTS SHOWN ON THIS PLAN ARE DIAGRAMATIC AND SHALL BE INSTALLED IN ACCORDANCE WITH SANITARY PLUMBING AND DRAINAGE DIRECTIONS - ALL APPLICABLE PARTS AMENDED. ENSURE SEWER TRENCH IS 900mm MIN. FROM FOOTINGS. DATUM FOR LEVELS - TBM AS SHOWN.
- S11. LAGGING IS REQUIRED, 40mm CLOSED CELL POLYETHYLENE.
- S13. FLEXIBLE SEWER & STORMWATER CONNECTIONS ARE REQUIRED.

**LEGEND**

- +100.00 EXISTING GROUND LEVEL
- 100.00 DESIGN LEVEL
- DP DOWNPIPE
- IP STORMWATER INSPECTION POINT
- STORMWATER PIPE 90Ø UPVC U.N.O. (MIN FALL 1:200)
- CONCRETE SUMP 300SQ x 3000 WITH MS GRATED COVER U.N.O.
- NEW BITUMEN PAVING
- EXISTING EMBANKMENT/BATTER
- EMBANKMENT/BATTER (GRADE BANKS 1:2 MAX)
- SPOON DRAIN (MIN FALL 1:200)
- UNLINED OPEN DRAIN (MIN FALL 1:100)
- SEWER PIPE (MIN FALL 1:50)
- GRATED TRENCH DRAIN (MIN FALL 1:200)
- KERB
- KERB & GUTTER
- 90Ø GRATED SURFACE S/W SUMP

|   |                               |    |          |
|---|-------------------------------|----|----------|
| F | U/G DETAILS AMENDED           | MT | 11.01.17 |
| E | DETAILS AMENDED               | MT | 09.01.17 |
| D | U/G TANK ADDED.               | MT | 21.12.16 |
| C | SWALE ADDED.                  | MT | 16.12.16 |
| B | ADDITIONAL INFORMATION ADDED. | MT | 06.12.16 |

**AMENDMENTS**

**ZAFIRIS & ASSOCIATES PTY. LTD.**  
 CONSULTING CIVIL & STRUCTURAL ENGINEERS  
 UNIT 7, 467 FULLARTON ROAD, HIGHGATE, S.A. 5063  
 PHONE: (08) 8299 9908 FAX: (08) 8299 9907 EMAIL: zafiris@odena.com.au

NEVER SCALE DRAWING, FIGURED DIMENSIONS TAKE PREFERENCE OVER SCALE. VERIFY ALL DIMENSIONS PRIOR TO COMMENCING ANY WORK.

SITE: **PROPOSED RESIDENCES FOR: TILTBUILD PTY LTD AT: 10 GUM AVE. DRY CREEK**

**SITE & DRAINAGE LAYOUT PLAN**

|                            |                        |                            |
|----------------------------|------------------------|----------------------------|
| DESIGN: <b>HRV</b>         | CHECKED: <b>TAZ</b>    | JOB NUMBER: <b>2160401</b> |
| DRAWN: <b>HRV</b>          | DATE: <b>16 DEC'16</b> | SCALE: <b>AS SHOWN</b>     |
| DRAWING NUMBER: <b>CF5</b> | ISSUE: <b>E</b>        |                            |

PLOT DATE: 04.01.17